



APPLICATION PACKET FOR:

TRI General Improvement District

**Water and Sewer
Will Serve Commitments**

Applicant must receive a water & sewer will serve commitment from TRI General Improvement District prior to obtaining its building permit from Storey County. (Grading only permits require no approvals from TRI General Improvement District)

Items required for water/sewer will serve commitment review:

1. TRI General Improvement District Service Application and Agreement (filled out and signed by *owner* – not by contractor);
2. (1) set of wet stamped civil drawings;
3. (1) set of landscape plans;
4. (1) set of mechanical/plumbing plans showing all plumbing fixtures;
5. Plan check fees, *see* “FEES” tab of “Water Letter Template”;
6. Inspection deposit, *see* “FEES” tab of “Water Letter Template”;
7. TRI Water Use Calculation Sheet, *see* “FEES” tab of “Water Letter Template” completed by registered engineer;
8. Sewer Pretreatment Checklist; and
9. Storey County parcel map.

Items required after review & prior to release of water/sewer will serve:

10. Additional water rights payment receipt, *see* “FEES” tab of “Water Letter Template” (if required);
11. Sewer connection fees, *see* “FEES” tab of “Water Letter Template”;
12. Water connection fees, *see* “FEES” tab of “Water Letter Template”;

Submit completed applications to:

John MacDonald
Farr West Engineering,
District Engineer
jmac@farrwestengineering.com
5510 Longley Lane
Reno, Nevada 89511
Phone: 775-851-4788



TRI GENERAL IMPROVEMENT DISTRICT

District Engineer –
 Farr West Engineering
 5510 Longley Lane
 Reno, NV 89511
 Office (775) 851-4788
 Fax (775) 851-0766

Sewer Pretreatment Checklist

Please review the following form. The maximum concentrations correspond to the highest level of constituent that may be discharged into the TRI General Improvement District sewer lines draining to the District wastewater treatment facility at any point of connection. Please sign at bottom of this sheet when finished.

Service Address: _____

<u>Constituent</u>	<u>Maximum Concentration</u>	<u>Concentration if Above Maximum</u>
Arsenic	0.05 mg/L	
Barium	4 mg/L	
Boron	1 mg/L	
Cadmium	0.01 mg/L	
Chromium	0.05 mg/L	
Copper	0.05 mg/L	
Cyanide	0.23 mg/L	
Iron	25.0 mg/L	
Lead	0.3 mg/L	
Manganese	0.7 mg/L	
Mercury	0.01 mg/L	
Nickel	1.80mg/L	
Selenium	0.04 mg/L	
Silver	0.05 mg/L	
TKN	40.0 mg/L	
Sulfate	240 mg/L	
Zinc	1.0mg/L	
Phenol	.005 mg/L	
Alkali	430 mg/L	
Chloride	110mg/L	
Phosphorus	8.0 mg/L	
TDS	500.0mg/L	
Fluoride	4.0 mg/L	

<u>Pesticides and Herbicides</u>	<u>Maximum Concentration</u>	<u>Concentration if Above Maximum</u>	
Total chlorinated hydrocarbons	0.005 mg/L		
Chlordane	0.005 mg/L		
Lindane	0.005 mg/L		
Heptachlor	0.005 mg/L		
Methoxychlor	0.005 mg/L		
Toxaphene	0.005 mg/L		
2-40	0.005 mg/L		
2-4-ST	0.005 mg/L		
Parathio	0.0016 mg/L		
Malathion	0.004 mg/L		
Guthion	0.004 mg/L		

<u>Other Constituents</u>	<u>Maximum Concentrations</u>	<u>Concentration if Above Maximum</u>
BOD 5	240 mg/L	
TSS	240mg/L	
PH	7-9	

I have reviewed the above maximum concentration levels and hereby state that the discharge for my development into the TRI General Improvement District sewer lines will contain no constituents in excess of the maximum concentration levels stated above (except those noted in the far-right column).

Signature: _____ Date: _____

Name and Title: _____